

CFH's BASED UPON 1000BTU/CFH

GENERAL \FCRMATIO\

10/1/98

1. DRAINAGE PIPING SERVING FIXTURES WHICH HAVE FLOOD LEVEL RIMS LOCATED BELOW THE ELEVATION OF THE NEXT UPSTREAM MANHOLE COVER OF THE PUBLIC OR PRIVATE SEWER SERVING SUCH DRAINAGE PIPING SHALL BE PROTECTED FROM BACKFLOW OF SEWAGE BY INSTALLING AN APPROVED TYPE BACKWATER VALVE. FIXTURES ABOVE SUCH ELEVATION SHALL NOT DISCHARGE THROUGH THE BACKWATER VALVE.

SHALL BE PROTECTED FROM BACKFLOW OF SEWAGE BY INSTALLING AN APPROVED TYPE BACKWATER VALVE. FIXTURES ABOVE SUCH ELEVATION SHALL NOT DISCHARGE THROUGH THE BACKWATER VALVE.

2. DRAINAGE PIPING THAT ARE LOCATED BELOW THE CROWN LEVEL OF THE MAIN SEWER SHALL DISCHARGE INTO AN APPROVED WATERTIGHT SUMP OR RECEIVING TANK, SO LOCATED AS TO RECEIVE THE SEWAGE OR WASTES BY GRAVITY. FROM SUCH SUMP OR RECEIVING TANK, THE SEWAGE OR OTHER LIQUID WASTES SHALL BE LIFTED AND DISCHARGED INTO THE BUILDING DRAIN OR BUILDING SEWER BY APPROVED EJECTORS, PUMPS, OR OTHER EQUALLY EFFICIENT APPROVED MECHANICAL DEVICE.

3. THE MINIMUM SIZE OF ANY PUMP OR ANY DISCHARGE PIPE FROM A SUMP HAVING A WATER CLOSET CONNECTED THERETO SHALL BE NOT LESS THAN TWO (2) INCHES (51mm).

4. THE DISCHARGE LINE FROM SUCH EJECTOR, PUMP, OR OTHER MECHANICAL DEVICE SHALL BE PROVIDED WITH AN ACCESSIBLE BACKWATER OR SWING CHECK VALVE AND GATE VALVE. IF THE GRAVITY DRAINAGE LINE TO WHICH SUCH DISCHARGE LINE CONNECTS IS HORIZONTAL, THE METHOD OF CONNECTION SHALL BE FROM THE TOP THROUGH A WYE BRANCH FITTING. THE GATE VALVE SHALL BE LOCATED ON THE DISCHARGE SIDE OF THE BACKWATER OR CHECK VALVE.

 GATE VALVES, WHEN USED ON DRAINAGE WORK, SHALL BE FULL WAY TYPE WITH WORKING PARTS OF CORROSION RESISTANT METAL. SIZES FOUR (4) INCHES (102mm) OR MORE IN DIAMETER SHALL HAVE CAST IRON BODIES, AND SIZES LESS THAN FOUR (4) INCHES (102mm), CAST IRON OR BRASS BODIES.

	FIVTURES	WASTE FIXTURE COUNT FIXTURES TRAP ARM NUMBER UNITS 1991 TO					
NE.	FIATURES	SIZE		NUMBER OF FIXTURES	UNITS 1991 UPC TABLE 4-1, 1994 UPC TABLE 7-3	TOTAL FIXTURE UNITS	
PING	BATHTUB	1 1/2"		2	2	4	
OR HALL	BIDETS	1 1/2"		0	2	0	
	C. WASHER	2"		1	2	2	
WITH							
ROM SIDE	FLOOR DRAIN	1 1/2"		0	2	0	
AST	SHOWER	2"		0	2	0	
	LAUNDRY TUB	2"		0	2	0	
	SINK/DW	1 1/2"		1	2	2	
	311417/044	2" WASTE		1	2		
	BAR SINK			0	1	0	
	LAVATORY	1 1/4"		2	1	2	
	W. CLOSET	3"		2	4	8	
		I.	T	DTAL FIXTUI	RE UNITS	18	
	SUPPLY FIXTURE COUNT						
	FIXTURES	MINIMUM CONNECTIONS		NUMBER OF FIXTURES	UNITS 1991 UPC TABLE 10-1, 1994 UPC TABLE	TOTAL FIXTURE UNITS	
	BATHTUB	1/2"	H0T 1/2"	2	6-3 2	4	
	DAIITIOB	1/2	1/4			~	
	BIDETS	1/2"	1/2"	0	2	0	
	C. WASHER	1/2"	1/2"	1	6	6	
	LAUNDRY TUB	1/2"	1/2"	0	2	0	
	SHOWER	1/2"	1/2"	0	2	0	
	SINK	1/2"	1/2"	1	2	2	
		'-	, -		_		

DISHWASHER 1/2" 1/2" 1

BAR SINK | 1/2" | 1/2" | 0

HOSE BIBB | 1/2" | 1/2" | 2

W. CLOSET 3/8"

REFRIG. 1/2"

LAVATORY 3/8" 3/8" 2 1 2

LAWN SPRINK. 1/2" - 0 1/HEAD 0

TOTAL FIXTURE UNITS 29

1 0

SHEET CONTENT:

 $\angle$ 

PROJECT NO.:

RH99-1018

DRAWN BY:

PLAN

DATE: 19 OCT 99

REVISIONS

REVISIONS

Rev. DATE:

1
2
3
4

PLAN 1045

SHEET